



UNSTABLE SUBGRADE



MACHINE COMPACTED TRENCH BACKFILL



LIMITS OF SLOPING OR BENCHING OF TRENCH WALLS



UNDISTURBED GROUND

NOTES:

1. MIN. COVER TO BE BELOW FINAL STREET GRADE WHEN AVAILABLE.
2. TRENCH TO BE BRACED OR SHEETED AS NECESSARY FOR THE SAFETY OF THE WORKMEN AND PROTECTION OF OTHER UTILITIES IN ACCORDANCE WITH APPLICABLE LOCAL, STATE AND FEDERAL REQUIREMENTS.
3. TRENCH WIDTH SHALL NOT BE MORE THAN 16 INCHES NOR LESS THAN 12 INCHES WIDER THAN THE LARGEST OUTSIDE DIAMETER OF THE PIPE LAID THEREIN (BELL OR COUPLING O.D. IF APPLICABLE).
4. COMPACTION SHALL BE AS FOLLOWS: PIPE ZONE BEDDING 6 INCHES UNDER AND 12 INCHES OVER PIPE WILL REQUIRE 90% S.P.D., TRENCH ZONE ABOVE BEDDING MATERIALS, FULL TRENCH SECTION IN ROADWAY OR STREET R.O.W. LIMITS WILL REQUIRE 95% S.P.D. TRENCH ZONE ABOVE BEDDING MATERIALS, OUTSIDE OF STREET R.O.W. WILL REQUIRE 90% S.P.D.

DATE
7/2007



PLATTE CANYON
WATER & SANITATION DISTRICT

DRAWING
D.4S

SPECIAL BEDDING
DETAIL