



1. TRENCH WALLS TO BE SUPPORTED AS REQUIRED BY OSHA.
2. TRENCH BACKFILL SHALL CONTAIN NO ROCKS/STONES LARGER THAN 4" IN DIAMETER.
3. GEO-TEXTILE FABRIC TO COVER GRANULAR BEDDING MATERIAL, NO. 67.
4. AWWA C900 SANITARY SEWER WYES SHALL BE DR18 FOR NON-PRESSURE SEWER APPLICATION.

DATE  
10/25/2019



PLATTE CANYON  
WATER & SANITATION DISTRICT

DRAWING  
D.4S

**EXPANSIVE SOIL  
BEDDING DETAIL**