



NOTE:
NEOPRENE OR PVC RUNNERS MAY BE USED AS AN ALTERNATIVE TO TREATED REDWOOD.

PIPE DIA.	CASING PIPE		RUNNER SIZE
	MIN. O.D.	MIN. WALL THICKNESS	
8"	18"	0.282"	4" x 4"
10"	20"	0.344"	4" x 4"
12"	22"	0.344"	4" x 4"
16"	28"	0.406"	4" x 4"
20"	32"	0.469"	4" x 4"

DATE
7/2007



PLATTE CANYON
WATER & SANITATION DISTRICT

DRAWING
D.21S

PIPE CASING &
SLED DETAIL