



REINFORCEMENT STEEL

| PIPE I.D. | LONGITUDINAL BARS – LOCATION | | |
|-----------|------------------------------|--------|--------|
| 6 IN. | 4-NO. 4 BARS | 1 EACH | CORNER |
| 8 IN. | 4-NO. 4 BARS | 1 EACH | CORNER |
| 10 IN. | 8-NO. 4 BARS | 3 EACH | SIDE |
| 12 IN. | 8-NO. 4 BARS | 3 EACH | SIDE |
| 15 IN. | 8-NO. 4 BARS | 3 EACH | SIDE |
| 18 IN. | 8-NO. 4 BARS | 3 EACH | SIDE |
| 21 IN. | 12-NO. 4 BARS | 4 EACH | SIDE |
| 24 IN. | 12-NO. 4 BARS | 4 EACH | SIDE |
| 27 IN. | 12-NO. 4 BARS | 4 EACH | SIDE |
| 30 IN. | 12-NO. 4 BARS | 4 EACH | SIDE |
| 33 IN. | 12-NO. 4 BARS | 4 EACH | SIDE |
| 36 IN. | 16-NO. 4 BARS | 5 EACH | SIDE |

NOTE:

THE DISTRICT SHALL REVIEW THIS DETAIL FOR USE ON A CASE BY CASE BASIS. SPECIAL ENCASEMENTS MAY BE REQUIRED AT CREEK CROSSINGS AND CONDUIT CROSSINGS.

DATE
7/2007



PLATTE CANYON
WATER & SANITATION DISTRICT

DRAWING
D.22S

CONCRETE
ENCASEMENT
DETAIL