



**NOTES:**

1. A FULL DEPTH CHANNEL IS REQUIRED IN BENCH.
2. THE MINIMUM VERTICAL DROP THRU MANHOLE BASE SHALL BE 0.2'.
3. FOR VERTICAL DROPS IN EXCESS OF 18", AN OUTSIDE DROP MANHOLE IS REQUIRED.

DATE  
10/25/2019



PLATTE CANYON  
WATER & SANITATION DISTRICT

DRAWING  
D.5S

**BASE & DEFLECTOR  
DETAIL**